

BRIAN FOGAS. P.O.A.  
8714 N. 68<sup>TH</sup> ST.  
Brown Deer, WI

CERTIFICATE OF COMPLIANCE  
INSPECTION REPORT

ADDRESS: 3400 W. BRADLEY RD.

OWNER: \_\_\_\_\_

INSPECTION DATE: 9-30-97 3:00

H.V.A.C.

Built 1954  
Orig. Owners

Furnace/Boiler - Proper Installation  Yes  No

Comments: GAS BOILER deal. Rebuilt.

Air Conditioning - Proper Installation  Yes  No

Comments: NA.

Wall/Space Heater - Proper Installation  Yes  No

Comments: NA.

Fireplace - Proper Installation  Yes  No

Comments: (2) masonry 1 1st Floor Living Room  
1 - Basement

Wood Burning Appliance - Proper Installation  Yes  No

Comments: NA.

Other - Proper Installation  Yes  No

Comments: \_\_\_\_\_

**BUILDING**

Basement Remodeling - Proper Installation  Yes  No

Comments: UNFINISHED -

Screen/Patio Room - Proper Installation  Yes  No

Comments: N/A.

Misc. Remodeling - Proper Installation  Yes  No

Comments: \_\_\_\_\_

Garage - Proper Installation  Yes  No

Comments: Attached. 2 CAR

Stairways - Proper Installation  Yes  No

Comments: \_\_\_\_\_

ALSO outside Bilco Door & Stairway.

Handrails - Proper Installation  Yes  No

Comments: \_\_\_\_\_

Guardrails - Proper Installation  Yes  No

Comments: N/A.

Basement Bedroom(s)

Comments: N/A.

Polystyrene Insulation

Comments: ojs

Other - Proper Installation  Yes  No

Comments: \_\_\_\_\_

**FIRE CODE**

Smoke Detectors - Proper Installation  Yes  No

\* Comments:  No Smoke Detectors.

Fire Wall (Garage; breezeway) - Proper Installation  Yes  No

\* Comments: Firewall ATTIC. Scuttle in Garage to be 5/8" Drywall. Type X

Other - Proper Installation  Yes  No

Comments: \_\_\_\_\_

**PLUMBING**

Basement Toilet Room - Proper Installation  Yes  No

Comments: N/A.

Water Heater ~~Gas~~ (Gas)  (Electric) - Proper Installation  Yes  No

Comments: \_\_\_\_\_

Bar Sink /Darkroom Sink- Proper Installation  Yes  No

Comments: N/A.

Dishwasher - Proper Installation  Yes  No

Comments: N/A.

Fixtures Added - Proper Installation  Yes  No

Comments: Toilets.

Damaged Fixtures

Comments: \_\_\_\_\_

Other - Proper Installation  Yes  No

\* Comments: Provide Proper Waste & Vent for  
Clothes Washer Discharge. Properly Support  
Water Supply Connections,  
BROWN DEER CODE

Well System -  Working  Abandoned

\* Comments: on 9-22-97 abandoned by Cent  
Copy of Report? Albena Pbs.

Swimming Pool - Proper Installation  Yes  No

Comments: N/A

Sump Pump -  Yes  No

Comments: to front yard.

Address Numbers - Conforming  Yes  No

\* Comments: Provide visible Address #'s.  
midway along Driveway.

Other - Proper Installation  Yes  No

Comments: \_\_\_\_\_  
\_\_\_\_\_

**ELECTRIC**

Garage Wiring - Proper Installation  Yes  No

Comments: ✓  
\_\_\_\_\_

Garage Door Opener - Proper Installation  Yes  No

Comments: N/A  
\_\_\_\_\_

Basement Remodeling - Proper Installation  Yes  No

Comments: ✓  
\_\_\_\_\_

~~Air Conditioning~~/Heating Units - Proper Installation  Yes  No

Comments: ✓  
\_\_\_\_\_

Patio/Screen Room - Proper Installation  Yes  No

Comments: N/A  
\_\_\_\_\_

Lamp Post/Exterior Lighting - Proper Installation  Yes  No

Comments: Light Post. Front. YARD.  
\_\_\_\_\_

~~CAS. ELECT.~~  
Dryer/Range - Proper Installation  Yes  No

Comments: \_\_\_\_\_  
\_\_\_\_\_

Damaged Fixtures -  Remove  Replace

Comments: \_\_\_\_\_

Swimming Pool Wiring - Proper Installation  Yes  No

Comments: N/A.

Other - Proper Installation  Yes  No

Comments: Properly abandon exposed wiring from  
old remove package binder.

Additional Comments and/or Explanations: \_\_\_\_\_

\* Remove Spliced Wired Fluorescent  
Light Fixtures in Basement.