



Village of Brown Deer

4800 W. Green Brook Dr. Brown Deer, WI 53223-2496 Phone: (414) 357-0100 FAX 357-0154

June 15, 1994

Ms. Janet Augustine
3420 W. Bradley Rd.
Brown Deer, WI 53209

Re: Certificate of Compliance Inspection

Dear Ms. Augustine:

A recent inspection of your dwelling, located at 3420 W. Bradley Rd., disclosed the following violations of the Brown Deer Code of Ordinances:

BROWN DEER BUILDING/ELECTRICAL PERMITS

Section 30.36/Section 1-1.11

H.V.A.C. and Electrical Permits are required for the installation of a furnace. No permits were issued or authorized for the furnace that was recently installed in this dwelling. The necessary permits shall be obtained and the installation shall be inspected by the Brown Deer Electrical Inspector. Double Fees will be assessed due to the furnace being installed prior to the issuance of the proper permits.

BROWN DEER PLUMBING CODE

Section 1-1.03

A Plumbing Permit is required before any plumbing work commences. No permit was issued or authorized for the installation of the gas water heater in the basement of this dwelling. The installation shall be reviewed by a licensed Master Plumber and the proper chimney size shall be verified. The Plumbing Permit shall be obtained and double fees will be assessed due to the installation of the water heater commencing prior to obtaining the necessary approval and permit.

NATIONAL ELECTRICAL CODE

N.E.C. 334-3

The exposed B-X wiring at the air conditioner shall be reviewed by a licensed electrician and corrected to meet the minimum standards of the National Electrical Code. The Electrical Permit shall be obtained and the corrections shall be inspected by the Brown Deer Electrical Inspector.

The violations noted herein shall be corrected on or before July 15, 1994. Please notify my office at 357-0144 when the corrections have been made so a reinspection can be conducted and the Certificate of Compliance issued.

Sincerely,

Robert G. Premo
Building Inspector

RGP:ejb

1:30