

CERTIFICATE OF COMPLIANCE
INSPECTION REPORT

ADDRESS: 3510 W. BRADLEY RD.

OWNER: _____

INSPECTION DATE: _____

MAIL TO: 20333 W. MAIN ST.
VACKSON. 53037
DELORES MEHNERT.

BUILT 1958
2nd OWNER.
204

H.V.A.C.

Furnace - Proper Installation Yes No

Comments: N/A

Air Conditioning - Proper Installation Yes No

Comments: ~~Oil Fired~~ YES. AIR HANDLER
in ATTIC. old

Boiler - Proper Installation Yes No

Back Flow Prot.

Comments: OIL FIRED BOILER REQ.
UNDERGROUND OIL TANK UNKNOWN SIZE?

Wall/Space Heater - Proper Installation Yes No

Comments: N/A.

Fireplace - Proper Installation Yes No

Comments: MASONRY - 1 MAIN LEVEL 1- LOWER LEVEL.

Wood Burning Appliance - Proper Installation Yes No

Comments: N/A.

Other - Proper Installation Yes No

Comments: _____

BUILDING

Rec. Room - Proper Installation Yes No

Comments: yes. ok

Screen/Patio Room - Proper Installation Yes No

Comments: N/A

Kitchen Remod. - Proper Installation Yes No

Comments: DRIC

Garage - Proper Installation Yes No

Comments: 2-CAR ATTACHED.

Handrails - Proper Installation Yes No

Comments: _____

Guardrails - Proper Installation Yes No

Comments: N/A

Stairways - Proper Installation Yes No

Comments: _____

Basement Bedroom

Comments: N/A

Polystyrene Insulation

Comments: N/A

Other - Proper Installation Yes No

Comments: _____

FIRE CODE

Smoke Detectors - Proper Installation Yes ___ No - Correct # Yes ___ No

Comments: _____

Fire Wall, Garage - Proper Installation Yes ___ No

Comments: _____

Other - Proper Installation ___ Yes ___ No

Comments: _____

PLUMBING

Basement Toilet Room - Proper Installation Yes ___ No

Comments: 1/2 Bath. DRIB.

Water Heater - Proper Installation Yes ___ No

Comments: 80 GAL ELect.

Dishwasher - Proper Installation ___ Yes ___ No

Comments: N/A.

Bar Sink - Proper Installation Yes ___ No

Comments: Wet Bar. DRIB.

Darkroom Sink - Proper Installation ___ Yes ___ No

Comments: N/A

Fixtures Added - Proper Installation ___ Yes ___ No

Comments: Remove improperly installed Shower in Basement Disconnect WATER Lines.

PLUMBING (cont.)

Damaged Fixtures

Comments: _____

Other - Proper Installation ___ Yes ___ No

Comments: _____

BROWN DEER CODE

Well System - ___ Working ___ Abandoned

* Comments: ✓ Service Well pump Pressure Controls & ? ~~Hand pump~~ installation

Swimming Pool - Proper Installation ___ Yes ___ No

Comments: N/A

OFF CASING ? to be RAISED.

Sump Pump - Proper Installation & Discharge Yes ___ No

Comments: ✓

Address Numbers - Conforming ___ Yes ___ No

Comments: ✓

Other - Proper Installation ___ Yes ___ No

Comments: _____

ELECTRIC

* Garage Door Opener - Proper Installation ___ Yes ___ No

Comments: ✓ Cord wired

Basement Remodeling - Proper Installation Yes ___ No

Comments: ✓

Air Conditioning/Heating Units - Proper Installation Yes ___ No

Comments: ✓

ELECTRIC (cont.)

✓ Garage Wiring - Proper Installation ___ Yes ___ No

Comments: Remove or Rewire Cord Wired
Lights in Garage & Basement

Patio/Screen Room - Proper Installation Yes ___ No

Comments: _____

Swimming Pool Wiring - Proper Installation ___ Yes ___ No

Comments: N/A

Lamp Post/Exterior Lighting - Proper Installation Yes ___ No

Comments: _____

Elect Elect
Electric Dryer/Range - Proper Installation ___ Yes ___ No

Comments: 220

* Damaged Fixtures - ___ Remove ___ Replace

Comments: Excessive B-X Wiring below Kitchen
Sink ✓ on Switch below Sink ASK RICK

Other - Proper Installation ___ Yes ___ No

Comments: _____

* LABEL Elect. Circuit Panels in GARAGE.

* OVERHEAD ELECTRICAL WIRES 10' CLEARANCE
ABOVE DRIVEWAY. ? ✓ with RICK.

ILHR 16.25-2 (2)