

Wisconsin Electric Power Company
OUTLET LOCATION LETTER

REVISION
 DUPLICATE
9-4-92

To: J. 0437 Electric Date Prepared _____

In regard to your inquiry of _____ for (Overhead) (Underground) service to the (Industrial) (Commercial) (residential) (farm) premise of Mark Griffin located at 3528 W. Bradley Rd.

In the C/T/V of Brown Deer we require service termination as follows:

New Temporary Rewired Additional
Single Phase 100 amperes, 120/240 volts, termination located 10-12-92
West Wall

at 13 foot minimum above (ground) (~~final grade~~)

per Electric Service and Metering Manual Sheets 0-2, 0-3, 0-10, m-4, m-5, m-9

Meter Location (out) (in) side at: termination

Service (drop) (lateral) size 4TX length 96' tension 458 lbs

Maximum Single-phase Available Short Circuit Current at the service termination.

10,000 amperes 22,000 amperes _____ amperes

New Temporary Rewired Additional Power
(Single) (Three) Phase _____ amperes (240) (120/208) (480) _____ volts, termination located _____

at _____ foot minimum above (ground) (final grade).

per Electric Service and Metering Manual Sheets _____

Meter Location (out) (in) side at: _____

Service (drop) (lateral) size _____ length _____ tension _____

Maximum (Single) (Three) phase Available Short Circuit Current at the service termination.

22,000 amperes 25,000 amperes _____ amperes

Installation of WE facilities involves (additional) charges. Billing must be satisfied prior to construction.

The above information is valid for 1 year

The above information is contingent upon right-of-way.

The above information is contingent upon _____

You are advised NOT to proceed with completion of wiring until notified the contingencies noted above have been removed.

On _____ you were advised not to proceed with the completion of the wiring. All the contingencies have been removed and you may proceed.

You may proceed with the completion of wiring.

The location of service drops supports for buildings covered with aluminum, stucco, asbestos, or other similar siding material shall be marked. Mounting bolts were provided by the Company and shall be installed by the owner, or by his contractor for him, on brick and stone buildings.

Refer Inquiries to L. Strassburg

NOTICE TO CUSTOMER/ELECTRICIAN

Prepared by Culumat District _____

Phone 362-5141

Information provided in this letter does not supersede the National, State or Local Electrical Codes. The final responsibility for compliance with the various electrical codes lies with the customer and/or the customer's electrician.

Clerk: Send this form to _____