

CERTIFICATE OF COMPLIANCE  
INSPECTION REPORT

ADDRESS: 4016 W. Calumet.

OWNER: \_\_\_\_\_

INSPECTION DATE: \_\_\_\_\_

CC: to buyer Kelly Dirk Built 1949.  
orig. owner.

H.V.A.C.

Furnace - Proper Installation  Yes  No

Comments: GAS FORCED AIR. 7 MONTHS OLD  
✓ For Permit by Deen's.

Air Conditioning - Proper Installation  Yes  No

Comments: N/A.

Boiler - Proper Installation  Yes  No

Comments: N/A

Wall/Space Heater - Proper Installation  Yes  No

Comments: N/A

Fireplace - Proper Installation  Yes  No

Comments: N/A

Wood Burning Appliance - Proper Installation  Yes  No

Comments: N/A.

Other - Proper Installation  Yes  No

Comments: DAMAGED MASONRY CHIMNEY CONNECTION. Interior Flue Liner  
DAMAGED - Improperly abandoned  
Furnace vent connection.

shall be repaired including the clay lined flue liners or unused vent sections

sect.

30.39 2. 3.

BUILDING

Rec. Room - Proper Installation  Yes  No

Comments: unfinished Basement

Screen/Patio Room - Proper Installation  Yes  No

Comments: N/A.

Kitchen Remod. - Proper Installation  Yes  No

Comments: ORIG.

\* Garage - Proper Installation  Yes  No

Comments: Detached 2-CAR.  
Replace Roof - Repair + Extend Replace  
DAMAGED WOOD

\* Handrails - Proper Installation  Yes  No

Comments: HANDRAIL Basement Stair.

Guardrails - Proper Installation  Yes  No

Comments: ✓ N/A.

\* Stairways - Proper Installation  Yes  No

Comments: Cracked bottom tread on  
STAIRWAY must be repaired or replaced.

Basement Bedroom

Comments: N/A.

Polystyrene Insulation

Comments: N/A.

Other - Proper Installation  Yes  No

Comments: \_\_\_\_\_

FIRE CODE

Smoke Detectors - Proper Installation \_\_\_ Yes \_\_\_ No - Correct # \_\_\_ Yes \_\_\_ No

Comments: 1 - Basement. Detected.

Fire Wall, Garage - Proper Installation \_\_\_ Yes \_\_\_ No

Comments: N/A.

Other - Proper Installation \_\_\_ Yes \_\_\_ No

Comments: \_\_\_\_\_

PLUMBING

Basement Toilet Room - Proper Installation \_\_\_ Yes \_\_\_ No

Comments: N/A.

Water Heater - Proper Installation \_\_\_ Yes \_\_\_ No

Comments: Gas. New. Improper Vent Correction to Close To Combustibles Flat Rate Dbb. ✓ For Permit.

Dishwasher - Proper Installation \_\_\_ Yes \_\_\_ No

Comments: N/A.

Bar Sink - Proper Installation \_\_\_ Yes \_\_\_ No

Comments: N/A.

Darkroom Sink - Proper Installation \_\_\_ Yes \_\_\_ No

Comments: N/A.

Fixtures Added - Proper Installation \_\_\_ Yes \_\_\_ No

Comments: N/A.

PLUMBING (cont.)

Damaged Fixtures

Comments: \_\_\_\_\_  
\_\_\_\_\_

Other - Proper Installation \_\_\_ Yes \_\_\_ No

Comments: \_\_\_\_\_  
\_\_\_\_\_

BROWN DEER CODE

Well System - \_\_\_ Working  Abandoned

Comments: *shared Well with Neighbor  
abandoned.*

Swimming Pool - Proper Installation \_\_\_ Yes \_\_\_ No

Comments: *N/A.*

Sump Pump - Proper Installation & Discharge \_\_\_ Yes \_\_\_ No

Comments: *Real Lawn.  
Rigid Discharge Piping Required*

Address Numbers - Conforming  Yes \_\_\_ No

Comments: \_\_\_\_\_  
\_\_\_\_\_

Other - Proper Installation \_\_\_ Yes \_\_\_ No

Comments: *NO STORAGE SHEDS.*

ELECTRIC

Garage Door Opener - Proper Installation \_\_\_ Yes \_\_\_ No

Comments: *N/A*

Basement Remodeling - Proper Installation \_\_\_ Yes \_\_\_ No

Comments: *✓ N/A*

Air Conditioning/Heating Units - Proper Installation \_\_\_ Yes \_\_\_ No

Comments: *Separate Circuit & Permit*

ELECTRIC (cont.)

Garage Wiring - Proper Installation  Yes \_\_\_ No

Comments:

Patio/Screen Room - Proper Installation \_\_\_ Yes \_\_\_ No

Comments: N/A

Swimming Pool Wiring - Proper Installation \_\_\_ Yes \_\_\_ No

Comments: N/A

Lamp Post/Exterior Lighting - Proper Installation \_\_\_ Yes \_\_\_ No

Comments: N/A

Electric  
Electric Dryer/Range - Proper Installation \_\_\_ Yes \_\_\_ No

Comments: See Note below.

Damaged Fixtures - \_\_\_ Remove \_\_\_ Replace

Comments: \_\_\_\_\_

Other - Proper Installation \_\_\_ Yes \_\_\_ No

\* Comments: improperly wired G.F.C.I Outlet in Bathroom

\* 60amp service no space circuits  
for. Fuses installed. Upgrade Necessary.

\* Review wiring to Range & Dryer by Licensed Elect.