



# Village of Brown Deer

4800 W. Green Brook Dr. Brown Deer, WI 53223-2496 Phone: (414) 357-0100 FAX 357-0154

August 1, 1994

Mr. Scott Bell  
4020 W. Calumet Rd.  
Brown Deer, WI 53209

OK  
9-2-94  
NH

Re: Swimming Pool Compliance

Dear Mr. Bell:

A recent inspection of your swimming pool disclosed the following violation of the Brown Deer Swimming Pool Ordinance:

Section 9-6.03 (b) 1.

A fence or other solid structure of no less than five (5) feet in height shall completely enclose said premises and/or swimming pool. Fences shall be located a minimum of four (4) feet beyond the outside perimeter of the swimming pool. There shall be no opening in said fence or wall larger than four (4) inches square.

Section 9-6.03 (b) 1.

All gates or doors opening through a fence or other solid structure enclosing a pool shall be equipped with a self-closing and self-latching device designed to keep such door or gate securely closed. Latches shall be located at least (48) inches above the ground, accessible deck or stairs.

This violation shall be corrected on or before August 16, 1994. Please notify my office at 357-0144 when the correction has been made so a reinspection can be conducted.

Sincerely,

Robert G. Premo  
Building Inspector

RGP:ejb

Mail Copy